



GADARK LAB PVT. LTD.

INDUSTRIAL ANALYSTS & CONSULTANTS

LAB. : H-54, Additional M.I.D.C. Kudal, Taluka - Kudal, District - Sindhudurg - 416 525.

Tel. : (02362) 223519 • email : info@gadark.in

OFF. : 15, Hindustan Kohinoor Industrial Complex, L.B.S. Marg, Vikhroli (West), Mumbai - 83.

Tel. : (022) 25777069 / 70 • Fax : (022) 25774545

TEST CERTIFICATE

Doc.No : GLPL/QF/5.10/01

Test Certificate No.	GS/K/17/0504	T.C. Date:	25/05/2017
Customer Name and Address	M/s. J.P. INFRA (MUMBAI) PVT. LTD. (SKYLARK REALTORS PVT. LTD.PLOT C PROJECT) KASHIMIRA, VINAY NAGAR, MIRA ROAD (EAST), THANE.		
Letter Ref/Date	---		
Lab Reference No.	9582	Page No.	1 of 1
Sampling Done By	Customer	Sample Received on	16/05/2017
Sample Submitted by	Customer On 15/05/2017	Analysis Period	16/05/2017 To 25/05/2017
Sample Description	Soil Sample From Back Side of Sales Building, 1 kg in plastic bag		

ANALYSIS REPORTS:

Parameters	Units	Test Result	Specification Range as per ICAR Critical Range
pH (1:5 Suspension)	---	7.14	6.5 – 7.5
Available Nitrogen	Kg/Hect.	282.24	250 – 500
Available Phosphorous	Kg/Hect.	10.5	10 – 30
Available Potassium	Kg/Hect.	32.0	100 – 250
Sodium Absorption Ratio	---	7.8	----
Water Holding Capacity	%	55.9	----

End

For GADARK LAB PVT. LTD.

AUTHORISED SIGNATORY
[KAILAS V. CHITALKAR]

CHECKED BY

Note:

1. Results relate only to the sample/s tested, only in case of samples submitted by customer & not drawn by GLPL.
2. Test certificate shall not be reproduced except in full, without written approval of the laboratory.
3. Samples will be preserved for a period 15 days from the delivery of Test Certificate.



GADARK LAB PVT. LTD.

INDUSTRIAL ANALYSTS & CONSULTANTS

LAB. : H-54, Additional M.I.D.C. Kudal, Taluka - Kudal, District - Sindhudurg - 416 525.

Tel. : (02362) 223519 • email : info@gadark.in

OFF. : 15, Hindustan Kohinoor Industrial Complex, L.B.S. Marg, Vikhroli (West), Mumbai - 83.

Tel. : (022) 25777069 / 70 • Fax : (022) 25774545

TEST CERTIFICATE

Doc.No : GLPL/QF/5.10/01

Test Certificate No.	GW/O/17/1494	T.C. Date:	20/05/2017
Customer Name and Address	M/s. J.P. INFRA (MUMBAI) PVT. LTD. (SKYLARK REALTORS PVT. LTD.PLOT C PROJECT) KASHIMIRA, VINAY NAGAR, MIRA ROAD (EAST), THANE.		
Letter Ref/Date	---		
Lab Reference No.	GW/O/17/1494	Page No.	1 of 1
Sampling Done By	GLPL On 15/05/2017	Sample Received on	16/05/2017
Sample Collected by	GLPL	Analysis Period	16/05/2017 To 20/05/2017
Sample Description	Borewell Water Sample, 1 lit in plastic bottle & 100 ml in glass bottle		

ANALYSIS REPORTS:

Parameters	Units	Test Result	Specification Range as per IS 10500 / 2012		Methods
			Requirement Acceptable Limit	Permissible Limit in the Absence of Alternate Source	
pH	---	7.96	6.5 – 8.5	No Relaxation	APHA 4500 H ⁺
Turbidity	NTU	0.6	1.0 Max.	5.0 Max.	APHA 2130 B
Total Hardness as CaCO ₃	mg/ltr	1156	200.0 Max.	600.0 Max.	APHA 2340 C
Calcium	mg/ltr	363.93	75.0 Max.	200.0 Max.	APHA 3500 Ca B
Magnesium	mg/ltr	60.43	30.0 Max.	100.0 Max.	APHA 3500 Mg B
Chlorides	mg/ltr	2255.92	250.0 Max.	1000.0 Max.	APHA 4500 Cl ⁻ B
Sulphates	mg/ltr	365.00	200.0 Max.	400.0 Max.	APHA 4500 SO ₄ ²⁻ E
Alkalinity	mg/ltr	198	200.0 Max.	600.0 Max.	APHA 2320 B
Total Dissolved Solids at 180°C	mg/ltr	4128	500.0 Max.	2000.0 Max.	APHA 2540 C
Iron	mg/ltr	0.318	0.3 Max.	No Relaxation	APHA 3111 B

BACTERIOLOGICAL TEST :

E. Coli	/ 100 ml	21	Shall not be detectable (Absent)	APHA 9221 F
Total Coliform Bacteria	/ 100 ml	71600	Shall not be detectable (Absent)	APHA 9221 C

REMARK - The Water sample is Non Potable as per IS 10500 / 2012 in respect of above tests.

End

For GADARK LAB PVT. LTD.

AUTHORISED SIGNATORY
[KAILAS V. CHITALKAR]

CHECKED BY

Note:

1. Results relate only to the sample/s tested, only in case of samples submitted by customer & not drawn by GLPL.
2. Test certificate shall not be reproduced except in full, without written approval of the laboratory.
3. Samples will be preserved for a period 15 days from the delivery of Test Certificate.



GADARK LAB PVT. LTD.

INDUSTRIAL ANALYSTS & CONSULTANTS

LAB. : H-54, Additional M.I.D.C. Kudal, Taluka - Kudal, District - Sindhudurg - 416 525.

Tel. : (02362) 223519 • email : info@gadark.in

OFF. : 15, Hindustan Kohinoor Industrial Complex, L.B.S. Marg, Vikhroli (West), Mumbai - 83.

Tel. No. : (022) 25777069 / 70 • Fax : (022) 25774545

TEST CERTIFICATE

Doc.No : GLPL/QF/5.10/01

Test Certificate No.	GA/17/05/176	T. C. Date	19/05/2017
Customer Name and Address	M/s. JP. INFRA (MUMBAI) PVT. LTD. (SKYLARK REALTORS PVT. LTD. PLOT C PROJECT) KASHIMEERA, MIRA ROAD (EAST), THANE.		
Letter Ref / Date .	---		
Measurement Done By	GLPL	Page No.	1 of 1

NOISE LEVEL MEASUREMENT DURING DAY TIME :

Date of Measurement	15/05/2017
Time of Measurement	14:45 Hrs.

Sr. No.	LOCATION	NOISE LEVEL dB (A)
01	Near Compound Wall West Side	65.8
02	Near Compound Wall East Side	61.6
03	Near Compound Wall North Side	64.2
04	Near Compound Wall South Side	62.9

End

For GADARK LAB PVT. LTD.

AUTHORISED SIGNATORY
[KAILAS V. CHITALKAR]

CHECKED BY

Note :

1. The results relate only to the samples tested
2. Test certificate shall not be reproduced except in full, without written approval of the laboratory.
3. Test Results relate only to the conditions prevailing at the time of sampling



GADARK LAB PVT. LTD.

INDUSTRIAL ANALYSTS & CONSULTANTS

LAB. : H-54, Additional M.I.D.C. Kudal, Taluka - Kudal, District - Sindhudurg - 416 525.

Tel. : (02362) 223519 • email : info@gadark.in

OFF. : 15, Hindustan Kohinoor Industrial Complex, L.B.S. Marg, Vikhroli (West), Mumbai - 83.

Tel. No. : (022) 25777069 / 70 • Fax : (022) 25774545

TEST CERTIFICATE

Doc.No : GLPL/QF/5.10/01

Test Certificate No.	GA/17/05/175	T. C. Date	19/05/2017
Customer Name and Address	M/s. JP. INFRA (MUMBAI) PVT. LTD. (SKYLARK REALTORS PVT. LTD. PLOT C PROJECT) KASHIMEERA, MIRA ROAD (EAST), THANE.		
Letter Ref / Date .	---		
Sampling Done By	GLPL	Page No.	1 of 1
Sample Received on	16/05/2017	Analysis Period	17/05/2017 To 19/05/2017

SAMPLING DETAILS - AMBIENT AIR MONITORING :-

Sampling Location	Near Main Gate			
Date of Sampling	15/05/2017			
Time of Sampling [Hrs]	13:30			
Duration of Sampling [Hrs]	24			
Ambient Temperature [°C]	Min.	33	Max.	37
Relative Humidity [%]	Min.	64	Max.	68

ANALYSIS REPORT :-

Parameters	Unit	Results	*N.A.A.Q.S.	Methods
PM ₁₀	µg/m ³	69.6	100.0	NAAQMS/36/2012-2013 Volume 1
PM _{2.5}	µg/m ³	43.2	60.0	NAAQMS/36/2012-2013 Volume 1
SO ₂	µg/m ³	36.1	80.0	IS 5182 (Part II) 2012
NO ₂	µg/m ³	39.6	80.0	IS 5182 (Part VI) 2012
CO	mg/m ³	1.38	2.0 for 8 Hrs.	IS 5182 (Part X) 1999
Lead	µg/m ³	< 0.01	1.0	NAAQMS/36/2012-2013 Volume 1
Ozone	µg/m ³	< 20.0	100.0 for 8 Hrs.	APHA Method 411 3 rd Edition
Ammonia	µg/m ³	< 14.0	400.0	APHA Method 401 3 rd Edition
Benzene	µg/m ³	< 0.14	5.0	IS 5182 (Part 11) 2006
Benzo Pyrene	ng/m ³	< 0.1	1.0	IS 5182 (Part 12):2004
Arsenic	ng/m ³	< 0.7	6.0	NAAQMS/36/2012-2013 Volume 1
Nickel	ng/m ³	< 6.0	20.0	NAAQMS/36/2012-2013 Volume 1

*N.A.A.Q.S. – National Ambient Air Quality Standards

End

For GADARK LAB PVT. LTD.

AUTHORISED SIGNATORY
[KAILAS V. CHITALKAR]

CHECKED BY

Note :

1. The results relate only to the samples tested
2. Test certificate shall not be reproduced except in full, without written approval of the laboratory.
3. Samples will be preserved for a period 15 days from the delivery of Test Certificate.
4. Test Results relate only to the conditions prevailing at the time of sampling

Recognised by Ministry of Environment, Forest and CC, Government of India, under the Environment Protection Act, 1986, vide Gazette Notification No. 1357, dated 2nd June 2016, valid upto 1st June 2021
ISO 9001:2008 Certified & BS OHSAS 18001:2007 Certified